

**2020 Colgate University Residential Building Fire Safety Notification**

<b>BUILDING</b>	<b>FIRE ALARM SYSTEM</b>	<b>FIRE ALARM COVERAGE</b>	<b>FIRE ALARM INSPECTION</b>	<b>SPRINKLER SYSTEM</b>	<b>SPRINKLER COVERAGE</b>	<b>SPRINKLER SYSTEM INSPECTION</b>
Andrews Hall	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Bryan Complex	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Burke Hall	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Curtis Hall	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Cutten Complex	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Drake Hall	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
East Hall	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Gate House	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Jane Pinchon Hall	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
La Casa Pan-Latina Americana House	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Newell Apartments	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Parker Apartments	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2019	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Stillman Hall	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Townhouses	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
University Court Apartments	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2019	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
Wendt University Inn	Yes	Common area coverage with zone addressing, individual rooms have stand alone devices/partial supervised system	JUNE / JULY 2019	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
West Hall	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
40 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
49 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
52 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
66 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
70 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
72 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
76 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
80 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
84 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
88 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
92 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
94 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
100 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
102 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
104 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
110 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
114 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
118 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020
100 Hamilton Street	Yes	Full coverage with addressable / supervised fire alarm system	JUNE / JULY 2020	Yes	Full coverage with wet sprinkler system and fire extinguishers	January 2020

The above-referenced Colgate University residential buildings are equipped with sprinkler systems and smoke and/or heat detection devices, including in sleeping areas, kitchens, hallways, and common areas. These detection devices report to a building fire alarm control panel that transmits alarm activations to a supervising station that is staffed 24 hours a day at Campus Safety. As per New York State fire code, the supervising station reports general alarm activations to the Madison County 911 Dispatch Center which, in turn, initiates local fire department response. In addition, a Campus Safety officer is deployed to investigate alarm activations. This document is provided pursuant to the requirements of New York State Education Law Section 6438 (the Kerry Rose Fire Sprinkler Notification Act). The entire annual Colgate University Fire Safety Report required by the federal Higher Education Opportunity Act can be accessed via the Colgate Clery Compliance webpage.