

**2022 Colgate University Residential Building Fire Safety Notification**

BUILDING	FIRE ALARM SYSTEM	FIRE ALARM COVERAGE	FIRE ALARM INSPECTION	SPRINKLER SYSTEM	SPRINKLER COVERAGE	SPRINKLER SYSTEM INSPECTION
100 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
100 Hamilton Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
102 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
104 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
110 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet (partial dry) sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
113 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
114 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
118 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet (partial dry) sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
40 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
49 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
52 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
66 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
70 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet (partial dry) sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
72 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
76 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
80 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet (partial dry) sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
84 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
88 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
92 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
94 Broad Street	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Andrews Hall	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet (partial dry) sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Bryan Complex	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Burke Hall	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Curtis Hall	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet (partial dry) sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Drake Hall	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet (partial dry) sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
East Hall	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Gate House	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Jane Pinchon Hall	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
La Casa Pan-Latina Americana House	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Newell Apartments	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet (partial dry) sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Parker Apartments	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet (partial dry) sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Stillman Hall	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
Townhouses	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
University Court Apartments	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months
West Hall	Yes	Full coverage with addressable / supervised fire alarm system	Summer 2022	Yes	Full coverage with wet sprinkler system and fire extinguishers	Annual Inspections June/July 2022 Quarterly Inspections every 3 months

The above-referenced Colgate University residential buildings are equipped with sprinkler systems and smoke and/or heat detection devices, including in sleeping areas, kitchens, hallways, and common areas. These detection devices report to a building fire alarm control panel that transmits alarm activations to a supervising station that is staffed 24 hours a day at Campus Safety. As per New York State fire code, the supervising station reports general alarm activations to the Madison County 911 Dispatch Center which, in turn, initiates local fire department response. In addition, a Campus Safety officer is deployed to investigate alarm activations. This document is provided pursuant to the requirements of New York State Education Law Section 6438 (the Kerry Rose Fire Sprinkler Notification Act). The entire annual Colgate University Fire Safety Report required by the federal Higher Education Opportunity Act can be accessed via the Colgate Clery Compliance webpage.